NATIONAL PARK SERVICE

United States Department of the Interior

NATIONAL PARK SERVICE Fire Island National Seashore 120 Laurel Street Patchogue, NY 11772

Review and Comments on Building/Zoning Permit Application

Applicant(s):

Owner: Nicole Mynarski

Tax Map #:

Application No.:

497-2.23

Receipt #42070

Zoning Authority:

Community:

Islip

Seaview

Object (Yes/No):

Yes

If Objection status is "Yes", property will be subject to the condemnation authority of the Secretary of the Interior, if built as proposed, or previously built with or without permits beyond allowable standards.

Reason for Objection: 36 CFR Part 28.12(d)

50 Of R 1 at 20.12(a)

Objection Type:

Exceeds 35% maximum lot occupancy

Comments:

The National Park Service objects to the overdevelopment of this property. The total lot occupancy exceedes 35%. In order to conform with Federal Zoning requirements, the overal development must be reduced.

Review of this application for construction or variance request within the Fire Island National Seashore is made in accordance with 36 C.F.R. Part 28, Federal Zoning Standards for Fire Island National Seashore.

Superintendent

Date

4/2015

Cc: Applicant